DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041

Water sample collected from "Inder Singh Public School" Plot 1, 2 & 3, A-Block, Shiv Vihar, Vikas Nagar, Uttam Nagar, Delhi – 110059 vide challan No- 39 Dated - 06.05.2025.
S1: DJB Stored water at above site. S2: Drinking Point (RO) at above site

THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY

S. No.	Particulars	Unit	Limit Acceptable	Limit Permissible	S1	S2
	PHYSICAL EXAMINATION					
1.	Date of collection	------	--	--	27.05.25	27.05.25
2.	Date of Analysis	------	--	--	29.05.25	29.05.25
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	------	No. Objectionable		No Obj	No Obj
5.	Turbidity	N.T.U.	1.0	5.0	3.2	2.0
6.	PH value	------	6.5	8.5	7.62	7.48
7.	Electrical Conductivity	µmho/cm	--	--	635	440
8.	Total dissolved solids	mg/l	500	2000	412	286
	CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	95	75
11.	Total Hardness	mg/l	200	600	175	110
12.	Calcium Hardness	mg/l	--	--	95	60
13.	Magnesium Hardness	mg/l	--	--	80	50
14.	Calcium as Ca	mg/l	75	200	38	24
15.	Magnesium as Mg	mg/l	30	100	19.2	12
16.	Ammonia as N	mg/l	0.5	N.R.	Nil	Nil
17.	Nitrite as N	mg/l	--	--	NIL	NIL
18.	Nitrate as NO_3	mg/l	45	N.R.	3.8	2.0
19.	Sulphate	mg/l	200	400	80	46
20.	Chloride	mg/l	250	1000	120	85
21.	Dissolved Iron	mg/l	1	N.R.	0.06	0.04
22.	Fluoride	mg/l	1	1.50	0.26	0.20
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.20	NIL
	BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS: As per tested parameters Samples S-1 & S-2 can be used for drinking purpose.

Asstt. Chief Water Analyst, DJB, Dairy No. 165, Date 16/06/25, Nangloi, Delhi-41

PRINCIPAL
INDER SINGH PUBLIC SCHOOL
VIKAS NAGAR, UTTAM NAGAR, DELHI-59

ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

BACT.

A/CHEMIST
INDER SINGH PUBLIC SCHOOL

Manager

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 06/11/2024

It is certified that an inspection team headed by ..Subhash Chander (S.I.).....

(Name of Officers with designation) from .....M.C.D.....PHED

inspected the Inder Singh Public School, Plot No-1,2,3 A-Block, Vikas Nagar, Uttam Nagar Delhi-110059

(Name & Address of the school) on 06/11/2024....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no.....205..... dated 14/03/2024.

of .....D.J.B. Nangloi Delhi..... (PHED Lab) certified that

the Inder Singh Public School.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...05/11/2025..

SUBHASH CHANDER
SI/DEMS/WZ/MCD
BMID-51607298

Signature with Seal: .....

Name : Subhash Chander

Designation : .....S.I.....

Name & Address of the Office / Department : D.E.M.S West Zone M.C.D

To

INDER SINGH PUBLIC SCHOOL

Plot No-1,2,3 A-Block, Vikas Nagar, Uttam Nagar, Delhi-110059

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PRINCIPAL
INDER SINGH PUBLIC SCHOOL
VIKAS NAGAR, UTTAM NAGAR, DELHI-1100

MANAGER
INDER SINGH PUBLIC SCHOOL
VIKAS NAGAR, UTTAM NAGAR, DELHI-110059